

Buildings and Grounds Report
Diocesan Assembly
November 3, 2018

Pavilion:

- Turned water on for summer months. Found a leak underneath the hand sink in the restroom and repaired it.
- Small hot water tank was not working. Replaced heating element.
- Gutters around pavilion were leaking at seams. Repaired with gutter sealer.

Storage Garage beside Pavilion:

- Had to make room for storage of items from the sale of the churches in Elwood City and Belaire, Ohio.
- Received \$500 for the sale of:
 - Old finish 3-point mower deck from old farm tractor; shaft broken; deck cracked—30 years old.
 - Old John Deere mower needed major repairs—27 years old.
 - Yard vac needed repairs to motor and tires—20 years old.
 - Trailer that was sitting on diocese property for several years had flat tires rotted deck boards, electrical wires in need of replacement—17 years old.

Received more money than if we would have sold all for scrap.

Chancery:

- Drain to sanitary sewer and lower drainage near Peters road was repaired by contractor; ground water was seeping into sanitary sewer.
- Raked ground where the two areas were covered with top soil and seeded it.
- Storm damage to tree in front of chancery garage area was cut up and removed so grass could be cut.

Respectfully submitted by:
Deacon Seraphim Truckley